



# PERMIT SONOMA FIRE PREVENTION DIVISION

FIRE SERVICES \* HAZARDOUS MATERIALS



<b>Address</b>	<b>Owner</b> 3210 West Dry Creek Rd, Healdsburg 2019 CFC Review Grading and Site Improvements				
09/01/2022	<b>SRA</b>	YES	<b>USE</b>	Residential	<b>Occupancy Class</b> R3/U
<b>SQFT Existing</b>	Not indicated		<b>SQFT NEW</b>	Not indicated	
<b>Stories</b>	Not indicated		<b>Height</b>	Not indicated	
<b>Construction Type</b>	Choose an item.		<b>Permit#</b>	GRD	22-0090
<b>Fire Sprinklers</b>	Req. NFPA 13D		<b>Fire Alarm</b>	N/A	
<b>Deferred Submittals</b>	Fire Sprinklers		N/A	N/A	N/A
<b>APN#</b>	090-140-038		<b>Fire Agency</b>	Gold Ridge FPD	
Martin L. Price (707) 279-4222			Martin.Price@sonoma-county.org		

**The project listed above has been reviewed and determined to be:**

- APPROVED:** No modifications required
- APPROVED AS NOTED:** minor modifications required - review attached comments
- NOT APPROVED:** revise and respond in writing per attached comments and resubmit. Revisions to the plans must be appropriately “clouded and keyed” or the resubmittal will not be accepted. Responses such as “plans comply” or “see plans” do not save time. Resubmittals received without a response letter will not be accepted.
- INCOMPLETE:** provide additional information per attached comments and resubmit; respond in writing.



# PERMIT SONOMA FIRE PREVENTION DIVISION

FIRE SERVICES \* HAZARDOUS MATERIALS



## **Inspections:**

Prior to final approval, all State and Local Codes shall be verified by field inspection by a member of the **Sonoma County Fire and Emergency Services Dept.** The following Inspections are required:

**Schedule of Inspections:** 707-565-3551 using the automated system of the Building Department.

- Fire Final (198)
- Fire Access/Water Supply (121)

## **Fire Conditions of Approval**

1. The following items will be verified during construction:
  - a. Vehicle gates at fire apparatus access roads. CFC Sec. 503.6 and Appendix D103.5.
  - b. Plans for fire safety during construction. CFC Sec. 3308.