



LABORATORIES, INC.

425 SOUTH E STREET • SANTA ROSA, CALIFORNIA 95404 • (707) 844-8807

August 8, 2005
Sample Collected: 07/23/05
Sample Received: 07/26/05
Collected By : Client

Luciani Pump
30 Mill Street
Healdsburg, CA. 95448

LOG NUMBER: 705-14254-6

Sample Description: Button

ANALYSIS

pH Std. units	7.2
Specific Conductance μ mhos/cm	430.
Total Hardness as CaCO ₃ mg/L	200.
Boron mg/L	<0.1
Nitrate mg/L	<2.0
Iron mg/L	0.28
Manganese mg/L	0.29

LIMITS

6.8 - 8.2	6000
900 μ mhos	6000
150+	HARD
1.0	6000
45	6000
< .3	6000/BARELY
.05	1716H

VERY TRULY YOURS,

BRELJE AND RACE LABORATORIES, INC.

MAY NEED MINOR TREATMENT

ANN HILL, LABORATORY MANAGER
AH:ljc

Received	_____	Pages	_____
Sign	_____	Date	_____
Sign	_____	Date	_____